

**Policy Statement #28(Water Utility Service Pipes)**

It shall be the policy of the Town of Parrsboro that all service pipes used in the Parrsboro Water Utility shall be less than 301 feet in length from the street to serviced building. Connections greater than 301 feet in length shall be made by extension of the water main. All services shall be Copper Type K. The size of the service pipe shall be as specified by the Utility depending on the projected demand of the customer. No pipe smaller than ¾" in diameter shall be laid for any service.

Date passed by Council: Special Council Meeting, August 21, 2008 #08-07