



**NOTES**

1. MINIMUM 300mm VERTICAL AND HORIZONTAL SEPARATION TO BE MAINTAINED BETWEEN WATER AND WASTE WATER/ STORM WATER PIPES.
2. PLACE SELECT BACKFILL MATERIAL, MAX. 50mm AROUND SERVICE BOX TO SUBGRADE.
3. PROVIDE 6.0m HORIZONTAL SEPARATION FROM ANY PORTION OF WASTE WATER DISPOSAL FIELD.
4. IT IS RECOMMENDED THAT THE NEED FOR A PRESSURE REDUCING VALVE IS DISCUSSED WITH YOUR PLUMBER. THE MUNICIPALITY IS NOT RESPONSIBLE FOR DAMAGE TO RESIDENT'S PLUMBING DUE TO OPERATIONAL PRESSURES.

WATER SERVICE LATERAL TRENCH INSTALLATION

**GUIDELINE  
WATER SERVICE LATERAL INSTALLATION  
MUNICIPALITY OF CUMBERLAND**

Drn. By :	Date : MAY 2019	Scale : NTS	Contract J47-27217
Checked	Date : MAY 2019	Revision. 0	Dwg. Sk1