

**T-MCC-2208**

**SUPPLY & DELIVERY OF HDPE PIPE AND FITTINGS**

**Addendum #2**

The below are answers to submitted questions:

- We are looking for 320kPa traffic grade pipe because we will be installing some sections under roads and driveways.
- The grates do not need to be traffic rated, they will be installed off the road.

**End of Addendum #2**